

ADDENDUM #3



PROJECT: 6530 Bridge Deck Replacement
BID NO: 19-043
FROM: Ryan Cushenan
DATE: January 6, 2020

Questions and Answers

1. *Are control joints required on the concrete bridge deck or approach slabs?*

Answer: No, because the reinforced concrete deck and approach slabs are being covered with a membrane and overlaid with asphalt, control joints are not required on these work elements.

Clarifications and Additions

1. None this addendum

Plan Revisions

1. None this addendum

Acknowledgement in Receipt of Addendum

FIRM NAME: _____

BY:(Printed) _____

BY:(Signature) _____ TITLE: _____

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.